

16 October 2012

Independent Competition & Regulatory Commission
(Att: Ms R Nayager, CEO)
PO Box 161
Civic Square ACT 2608

Dear Ms Nayager

Licence application by Roads ACT to supply non potable water

Confirming my earlier email to your Ms Musgrove, I would like to submit the following comments on the above application on behalf of ACTEW Water:

- ACTEW's concerns would be to ensure that there are sufficient protocols in place to maintain an acceptable level of separation between the new non-potable network and the existing potable water and sewer networks. This separation should be in terms such as: physical clearances; markings and colouring of pipe and fittings; lower operating pressures if possible; protocols to minimise the risk of cross connections; and suitable back flow controls.
- Connections may be permitted to the sewer network on a case by case basis, but only under strict controls to be determined with the new utility.

Please contact me if you require any further information.

Yours faithfully

A handwritten signature in black ink, appearing to read 'Des Allen'.

Des Allen
MANAGER WATER PLANNING
t 02 6242 1456 | f 02 6242 1406
email des.allen@actew.com.au